

TRUE COMFORT2400 de la Province
Longueuil, QC J4G 1G1C. client@truecomfortsystems.com T. 877-800-TRUE (8783)**True Comfort.****TEST LOG**

Fill in capital letters

PRODUCT INFORMATION

(see identification label)

Model number: _____

Length: _____

Resistance (Ω): _____

Voltage (V): _____

Output (W): _____

Production no.: _____

PS12030191		MODEL NO. NO. DE MODÈLE
58.2 m 191 ft/pi		LENGTH LONGUEUR
58	Ω	RESISTANCE RÉSISTANCE
120	V	VOLTAGE TENSION
645	W	RATED OUTPUT PUISSANCE NOMINALE
203192401461		PRODUCTION NO. NO. PRODUCTION

TESTS	Manufacturing values	Before breaking seal	After Installation	After cable covering	After flooring
Date (YYYY/MM/DD)	----				
Heating cable resistance (Ω)					
Insulation resistance (M Ω)	Infinite				
#1 floor sensor resistance (K Ω)	10 @ 25°C/77°F				
#2 floor sensor resistance (K Ω)	10 @ 25°C/77°F				
Tested by	----				

START DATE (YYYY/MM/DD): _____**CONSUMER**

First Name: _____

Last Name: _____

Address: _____

City, Prov., Postal Code: _____

Email Address: _____

Phone Number: _____

Room: _____

RETAILER

Company Name: _____

Address: _____

City, Prov.: _____

DATE OF PURCHASE(YYYY/MM/DD): _____New construction Remodel **CABLE INSTALLER**

First Name: _____

Last Name: _____

Company Name: _____

Address: _____

City, Prov.: _____

THERMOSTAT INSTALLER

First Name: _____

Last Name: _____

Company Name: _____

Address: _____

City, Prov.: _____

Keep a copy and return this Test Log to:

TRUE COMFORT, Customer Service, 2400, rue de la Province, Longueuil, QC J4G 1G1

Canada Or by Email to: client@truecomfortsystems.comFor full warranty details please visit the website www.truecomfortsystems.com

To initiate a claim under warranty, present this Test log with the purchase invoice.